



## ADDENDUM NUMBER ONE

June 3, 2024

### **Replace HVAC System at Florida and Fischer III Housing Communities IFB No. 24-912-29**

THIS ADDENDUM IS BEING ISSUED TO INCORPORATE THE FOLLOWING IN THE REFERENCED INVITATION FOR BIDS.

**INSERT: Pre-Bid Conference will be conducted on Thursday, June 13, 2024, at 10:30am followed by a site visit.**

#### **Zoom Link:**

<https://us02web.zoom.us/j/86582540310?pwd=ipke3lQwYQiZpS37T9A0ZLgOdFncdR.1>

**Delete: Bids Due Friday, June 14, 2024, by 2:30pm**

**Insert: Question Deadline: Friday, June 21, 2024, by 12:00pm**

**Insert: Bids Due: Tuesday, July 2, 2024, by 2:30pm**

Questions and Answers:

**Q: Our team has reviewed the information and there were no specifications on the Seer rating for the 3-ton HVAC systems, can you clarify?**

**A: HANO is looking for 3-ton 16-seer HVAC System.**

**Proposals must be received by the Housing Authority of New Orleans (HANO) in the Office of Procurement and Contracts by 2:30pm, local time on Tuesday, July 2, 2024.** All terms and conditions shall remain as stated in the original Request for Proposals. **All addenda must be acknowledged.**

**END OF ADDENDUM NUMBER ONE**